

South Coast Air Quality Management District

Facility Equipment List Report

Facility: 138823 MAERSK DISTRIBUTION SERVICES INC MR: Contact: LEWIS FAKKAS Jr. (323) 5682603
Last Inspection: 08/21/2012 TS: TS-11 Industrial: Sector-based Ins Quarter: 0010 - inspect in 3rd quarter, every year
SIC: Facility Status: Active On Hold: N Suspended: N
Inspector: HL02 HAY LO Assignment No. 1063049 Facility Team: J
Inspection Date: 08/12/2008 Disposition: Notice To Comply
Location Address: 5011 FIRESTONE PL, SOUTH GATE 90280-3533 Sector:LC
Mailing Address: 5011 FIRESTONE PL, SOUTH GATE 90280-3533 Sector:LC
Instruction:

RECLAIM: N		TITLE V: N		SIP:		AIR:	
Application No.	Permit No.	Permit Issue Date	Permit Status	Equipment Category	BCAT/CCAT Description	Application Date	Application Status
426851	F76105	06/16/2005	ACTIVE	043901 BCAT	I C E (50-500 HP) EM ELEC GEN-DIESEL	03/09/2004	PERMIT TO OPERATE GRANTED

Report: 08/12/2008- Applicable Rules: 1470, 203

At 1440 HRS, I arrived at Hudd Distribution Services, Inc., facility #138823, located at 5011 Firestone Place, South Gate 90280, to perform a compliance inspection. Hudd distribution is a large warehouse/storage and distribution center for retail stores like Wal-Mart and Sears. The facility has changed its name to Maersk Distribution as of the beginning of the year and has one emergency generator powered by a diesel-ICE, permit F76105. I met with Mrs. Gretchen Kiesselbach, Office Services Manager, who accompanied me during my inspection. The ICE is located outside in the parking lot area. ICE is rated at 151 bhp, has a serial # of YB50604U708557D and belongs to the engine family "XPKXL05-9YH1." The hour meter reading at the time of my inspection was 29.5 hrs. Mrs. Kiesselbach was not able to produce the maintenance and operating log for the ICE. I issued a notice to comply, NC D16739, to Mrs. Gretchen Kieseelbach, to update/change facility name and to provide maintenance/operating log to verify compliance with permit conditions and Rule 1470. I also left with Mrs. Kiesselbach the appropriate form to get the name changed. I departed the facility at 1530 HRS.

08/20/2008

Followup confirms that facility has complied with the NC by submitting business name change form and has provided maintenance logs. Facility is currently running 32 minutes per month, equivalent to approximately 6 hours per year, under their 20 hour limit.

Reviewed by MV on 8/21/2008.